



OFFICE OF THE EXECUTIVE ENGINEER,
P.H. DIVISION-I, CUTTACK.

Telephone/e-mail/FAX: 06712310115/eephictc@gmail.com

No. 14639 /Dt. 12-9-2018

To

M/s RSC Infratech Developers LLP,
S-90, Vijaya Sarita, Near-ST, Stephen School
Makarwali Road, Panchsheel Nagar, Ajmer, Rajasthan
Pin-305001.
e-mail: rsgroup1966@gmail.com

Sub: Procurement of Sluice valve, N.R. Valve, Air Valve, P.R.Valve in connection with the work "Improvement of WS to Cuttack (Clear Water Rising Main) (AMRUT/OD/CUTTACK/WS/43).

Ref: Your letter No.OD/PH/10 Dt.16.08.2018.

Sir,

With reference to the above cited subject mentioned, you are allowed to purchase Sluice valve, N.R. Valve, Air Valve, P.R.Valve for speedy execution of work from Super Valve Manufacturing Company, Howrah (WB) and B.M. Engineering, Rajkot (Gujarat) in addition to the approved vender list in the DTCN and exclusive list of the local MSEs having ISO/ISI/EPM certification to the stipulation of MSME development Act, as per instruction issued vide letter No.14602 dt.16.10.2017 of Engineer-in-Chief, P.H. Odisha, Bhubaneswar. The agency should be the manufacturer of valves and having valid BIS registration certificate and the materials procured shall be inspected by the third party inspecting agency as per relevant IS specification. The supply order along with the manufacturer test certificate and TPI report of above valves should be submitted to the Engineer-in-charge and EIL officials of Cuttack before utilisation in the work.

Yours faithfully,

[Signature] 12/9/18
Executive Engineer, (PH)

Memo No. 14640 /Dt. 12-9-2018

Copy submitted to the Engineer-in-Chief, P.H. Odisha, Bhubaneswar for favour of kind information and necessary action.

[Signature] 12/9/18
Executive Engineer, (PH)

Memo No. 14641 /Dt. 12-9-2018

Copy submitted to the Superintending Engineer, P.H. Circle, Cuttack for favour of kind information and necessary action.

[Signature] 12/9/18
Executive Engineer, (PH)

Memo No. 14642 /Dt. 12-9-2018

Copy to the Assistant Executive Engineer, W/S Sub-Division, Cuttack for information and necessary.

[Signature] 12/9/18
Executive Engineer, (PH)

Memo No. 14643 /Dt. 12-9-2018

Copy to V.S.V. Sudarshan, RCM, AMRUT Project, Odisha, EIL OUIDF Zone A/2, 4th floor Fortune Tower, Bhubaneswar/ EIL, AMRUT Cell, Cuttack for information and necessary action.

[Signature] 12/9/18
Executive Engineer, (PH)