

**GOVERNMENT OF TELANGANA**  
**DEPARTMENT OF MISSION BHAGIRATHA**  
**Proceedings of the Engineer-in-Chief, MB, Hyderabad**  
**Present: G. Krupakar Reddy, B.E.**

Procs No: Intra Village/DI Valves/RC/Super/MB/2016-17,  
dt:17.09.2019

**Sub:-** RWS&S Dept - Mission Bhagiratha - Rate Contract for Manufacture, Supply and Delivery of DI Valves - Extension of RC agreement Period - Reg.

**Ref:-** 1. M/s Super Valve Mfg Co., Lr. No.Nil, dt: 04.09.2019  
2. RC Agreement No: 06/DI Valves/MB/Intra Village/ Super/ 2016-17, dt: 20.06.2017 of ENC, RWS&S, Hyd.

-000-

**ORDER:**

As per the willingness submitted by the firm M/s Super Valve Mfg Co, Howrah vide reference 1<sup>st</sup> cited, the Rate Contract Agreement concluded through reference 2<sup>nd</sup> cited for DI Valves, is extended **up to 14.02.2020** with the same terms and conditions laid down in the original RC agreement and amendments/modifications issued from time to time.

Sd/- G.Krupakar Reddy  
Engineer-in-Chief,  
RWS&S, Hyderabad.

To

**M/s Super Valve Mfg. Co.,**

**29/2/3/1, Narasingha Dutta Road, Kadamta, Howrah-711101, WB.**

Copy to all the SEs/EEs, MB in the state for information and necessary action.


Copy to all the SEs/EEs (V&QC) in the state for information and necessary action.

Copy to all CEs, TDWSP, MB in the state for information and necessary action.

Copy submitted to the Secretary to Government, RWS&S Dept, Hyderabad for kind information.

Copy to Stock file.

///t. c. f. b. o.///

  
Deputy Executive Engineer,  
V&QC, MB, Hyderabad

**GOVERNMENT OF TELANGANA  
MISSION BHAGIRATHA DEPARTMENT**

**Proceedings of the Engineer-in-Chief, MB, Hyderabad.  
Present: Sri G. Krupakar Reddy, B.E.**

**Procs. No. AEE3/ DEE/Valves/Vendors Regn(02)/Super Valve Mfg.  
Co./V&QC/RWS&S/2016, dt: 31.08.2019**

Sub:- MB -TDWSP- Empanelment of Vendor Registration for DI Valves **(2nd spell)**  
**for Intra Village network** - Renewal - Orders issued - Reg.

- Ref:- 1. ENC, RWS&S, Hyd, Vendor Registration proceedings vide : AEE1/DEE/  
Valves/Vendors Regn(02)/Super Valve Mfg.Co./V&QC/RWS&S/2015,  
dt: 15.02.2017 (for PN 10 & 16).  
2. Application of M/s Super Valve Mfg. Co., Howrah., Lr No. Nil,  
dt: 05.07.2019  
3. Minutes of the Chief Engineer's Committee meeting held on 22.03.2018  
in the O/o ENC, RWS&S, Hyderabad  
4. The Executive Engineer, V&QC, MB, Hyderabad Division Lr. No.  
AEE1/Vendor Regn/Super Valve Mfg./2018/48, dt:28.08.2019

-000-

Through the reference 1<sup>st</sup> cited, Empanelment of Vendor Registration for Ductile Iron Valves (2<sup>nd</sup> spell) was given for the firm **M/s Super Valve Mfg. Co., 29/2/3/1, Narasingha Dutta Road, Kadamtala, Howrah - 711 101, West Bengal** for a period of two (2) years for pressure ratings of **PN 10 & 16**, having validity i.e., upto 14.02.2019.

Now, based on the references 2<sup>nd</sup> to 4<sup>th</sup> cited, it is proposed **for renewal** of vendor approval for intra village given for the said firm for further period of **two (2) years**, and all the conditions laid down in the proceedings issued vide 1<sup>st</sup> cited holds good.

a) Details of Dia and pressure rating of DI valves:

<b>DI Valves with Resilient seated</b>		<b>Air Valves</b>
Type of Valves	Gate valves	Single chamber air valve
Dia in mm	50 to 300	50 to 200
Pressure rating (PN)	10 & 16	10 & 16

1. The Manufacture of DI Valves shall be with DI of grade GGG 40/ SG400 or GGG50/ SG 500 or equivalent grade as per IS: 3896-part 2-1985 and subsequent revisions.
2. This registration is only for purchase of above materials for Telangana Drinking Water Supply Project and not for propagation furthering interest of marketing by publication in newspaper or advertising in any form.
3. The **Renewal** of vendor registration will be valid for a period of **2 years** only from the next date of validity of previously issued proceedings (**i.e., from 15.02.2019 to 14.02.2021**) and after review of performance and if satisfactory only vendor registration shall be extended for further period on par with other vendors registered. However, shifting of unit or any alteration activity carried out in the unit mentioned above will attract fresh shop inspection and



periodical renewal of relevant documents shall be brought to the notice of Dept. immediately.

4. The performance of DI Valves shall be reviewed for every 2 years at the usage ends by the Vig & Quality control wing of RWS&S dept and after fulfilment of satisfactory performance only, the vendor registration shall be extended for further period subject to fulfilment of the renewal terms and conditions.
5. During the vendor registration period of approved firm, if the products offered for inspection, rejected (or) the performance of the supplied materials is not satisfactory, then the firm registration will be cancelled and further renewal will not be accepted.
6. This approval does not mean a guarantee for purchase of materials mentioned above. The Dept. reserves right for cancellation of firm from vendor list without assigning any reason and also reserve the right and absolute discretion to call for the documents even during the validity of registration period. The Firm shall have to apply for re-registration well in advance i.e. three months prior to the expiry date of registration/approval.
7. During the currency of vendor registration, the clauses stipulated in the EOI at the time of vendor registration shall prevail.
8. The warranty period shall be minimum as stipulated in the agreement conditions of Dept. works.
9. Any discrepancy noticed in this proceedings shall be brought to the notice of the under signed within 15 days.

Sd/- G. Krupakar Reddy  
**Engineer-in-Chief, MB, Hyd**

To,

**M/s Super Valve Mfg. Co., 29/2/3/1,  
Narasingha Dutta Road, Kadamtala, Howrah - 711 101, West Bengal,**

Copy to all Superintending Engineers and Executive Engineers, MB Department in the State and with instructions to verify the relevant documents at the time of pre-delivery quality inspection of materials.

Copy to the Superintending Engineers, V&QC, MB Circle, Hyderabad & Warangal.


Copy to all Executive Engineers / Deputy Executive Engineers V&QC, MB in the State and with instructions to verify relevant QC test results/certificates of raw casting of valves, relevant certificates of Epoxy powder certified by GSK/WRAS/NSF, Food grade quality EPDM approved by DVGW/WRAS/NSF etc. at the time of pre-delivery quality inspection of materials.

Copy to all Chief Engineers Mission Bhagiratha in the state.

Copy submitted to the Secretary to CM & Secretary to Government, MB (FAC) department, Telangana Secretariat, Hyderabad for favour of information.

Copy to Spare Copy/SF.

//Authenticated//

  
Deputy Executive Engineer,  
V&QC, RWS&S, Hyd.

